

CERTIFICATE



HYGIENIC QUALIFICATION OF AIR PURIFICATION DEVICE ‚HEPA 1800 HT‘ BASED ON VDI 6022-1:2018-01

CONTRACTEE	Kurt Hüttinger GmbH & Co.KG
INSPECTED OBJECT	Air purification device mode: Luftklar HEPA 1800 HT
INSPECTED SCOPE	Evaluation of the hygienic safety and usability in medically used rooms without particular hygienic requirements (e.g. room class II) and conformity based on VDI 6022-1: 2018-01.
INSPECTION REPORT	37927-LR-GUT-1800-0321-A
INSPECTION RESULT	The hygienic harmlessness and conformity of the air purification device HEPA 1800 HT (with a HEPA filter of class H-14 according to DIN EN 1822-1:2019-10) based on VDI 6022-1:2018-01 is confirmed. A particulate and microbiological reduction in the room air has been demonstrated through the use of the air cleaning device.
DATE OF ISSUE	2021-03-26
AUTHORISATION	Dr. Frank Wille, Münster

Dr. Frank Wille